

Zertifikat

Certificate

Zertifikat Nr. Certificate No.
R 50482658

Blatt Sheet
0001

Ihr Zeichen Client Reference
X.X.B

Unser Zeichen Our Reference
01-Wuchale-60406192 001

Ausstellungsdatum
15.10.2020

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder
MAXGE ELECTRIC
TECHNOLOGY CO., LTD.
NO. 299 EAST CHANGHONG ROAD
DEQING ECONOMIC ZONE, WUKANG
DEQING
313200 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Plant
Refer to latest revision
of the annex list of factories

Prüfzeichen Test Mark



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111230393

Geprüft nach Tested acc. to
IEC 60947-3:2020

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Fuse Holder (Fuse-disconnector)

Type Designation : EPF 32PV
Utilization Category : DC-20B
Rated Operational Voltage (Ue) : DC 1000 V
Rated Operational Current (Ie) : 2 - 32 A
Rated Insulation Voltage (Ui) : 1000 V
Rated Impulse Withstand Voltage(Uimp) : 4 kV
Conventional Free Air Thermal Current(Ith): 32 A
Rated Conditional Short-circuit Current : 20 kA
Pollution Degree : 3

6

6

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Bo Liu